

1. SMOKE DETECTORS SHALL RECEIVE THEIR PRIMARY POWER FROM THE BUILDING WIRING AND SHALL BE INSTALLED IN ACCORDANCE WITH THE NATIONAL FIRE PROTECTION ASSOCIATION (NFPA) 720, 2013 EDITION, AND ALL SMOKE DETECTORS SHALL BE INTERCONNECTED.
2. FULL BATH MUST HAVE AT LEAST ONE LUMINAIRE WITH LAMPS WITH AN EFFICACY OF AT LEAST 40 LUMENS PER WATT.
3. SMOKE AND/OR HOT-TIME-SMOKE COMBINATIONS ARE TO BE PROVIDED WITH INDIVIDUAL CONTROL VALVES OF THE PRESSURE-BALANCE OR THE THERMOSTATIC WINDING VALVE TYPE. THE WATER TEMPERATURE SHALL BE IN A SETTING OF 120 °F.
4. A 22 x 30" ATTIC ACCESS IS REQUIRED FOR ALL ATTICS WHICH ARE MORE THAN 30" IN HEIGHT. THE ATTIC ACCESS NEEDS TO BE AN ACCESSIBLE, UNLOCKED, UNLATCHED, UNBARRICADED, UNLOCKED CLOSET SHED OR POLE 30" MINIMUM HEADROOM IS REQUIRED ABOVE THE ACCESS. ATTICS WITH EQUIPMENT NEED A 30" x 30" ACCESS.
5. EXCEPTIONS: THE ACCESS MAY BE 22 x 30" WHEN THE EQUIPMENT IS NOT MORE THAN 30" ABOVE THE EQUIPMENT CAN BE REMOVED THROUGH THE OPENING.
6. SHOWER WALLS SHALL BE FINISHED WITH A HARD, NON-FLAMMABLE SURFACE WITH LIGHT NO LESS THAN 70" ABOVE THE DRAIN INLET.
7. ARC-FAULT CIRCUIT INTERRUPTER PROTECTION: ALL BRANCH CIRCUITS OF 15 AMP, 25 AMP, 30 AMP, SINGLE-PHASE, 120/240 VOLT, 1-PHASE, 3-WIRE, LIGHTS, SMOKE, ALARMS, ETC., INSTALLED IN DWELLING UNIT REBERSOS SHALL BE PROTECTED BY AFCI. LISTED TO PROVIDE PROTECTION OF THE CIRCUITS. IN ADDITION TO OTHER BRANCH CIRCUIT REQUIREMENTS, AT LEAST ONE 20 AMP BRANCH CIRCUIT SHALL BE REQUIRED TO SUPPLY BRANCH RECEPTACLE OUTLETS, OTHER EQUIPMENT (LUMINAIRE, RECEPTACLE, ETC.) AND TO PROVIDE PROTECTION BY THE SAME BRANCH CIRCUIT WHERE THE BRANCH CIRCUIT SUPPLIES A SINGLE BATHROOM ONLY.
8. HYDROSCAPE TUBS AND THEIR ASSOCIATED ELECTRICAL COMPONENT ARE TO BE PROTECTED BY A GROUND FAULT CIRCUIT INTERRUPTER (AL 125 VOLT, SINGLE-PHASE RECEPTACLE NOT EXCEEDING 20 AMPS AND 125 VOLT, SINGLE-PHASE RECEPTACLE NOT EXCEEDING 20 AMPS OF THE INSIDE WALLS OF A HYDROSCAPE TUB ARE TO BE PROTECTED BY GFI).

\$	SWITCH
⌚	RECEPTACLE
⊕	LIGHT
110 V	
SD	SMOKE DETECTOR