

3. SHOWER AND/OR TUB-SHOWER COMBINATIONS ARE TO BE PROVIDED WITH INDIVIDUAL CONTROL VALVES OF THE PRESSURE BALANCE OR THE THERMOSTATIC TYPE. MAXIMUM IS A SETTING OF 120 °F. SHOWER WALLS SHALL BE FINISHED WITH A HARD, NON-ABSORBENT SURFACE TO A HEIGHT NOT LESS THAN 70" ABOVE THE DECK NUT.
4. A 22 "X 30" ATIC ACCESS IS REQUIRED FOR ALL ATIC ACCESS NEEDS TO BE IN AN ACCESSIBLE LOCATION. THE ACCESS SHALL BE PROVIDED BY A LOCKED CLOSET DOOR OR DOOR TO AN UNLOCKED CLOSET. THE ACCESS SHALL BE 22 "X 30" WHEN TRUSSES ARE TO BE REMOVED THROUGH THE OPENING.
5. MECHANICAL DEVICE CAPABLE OF PROVIDING 5 AIR CHANGES PER HOUR.
6. 42" HIGH TAILING WITH NO OPENING LARGER ENOUGH FOR A 4" SPHERE TO PASS THROUGH.
7. ALL RECEPTACLE OUTLETS INSTALLED IN BEDROOMS TO BE PROTECTED BY AN ARC-FAULT CIRCUIT INTERRUPTER.

	SWITCH
	RECEPTACLE
	LIGHT
	FAN LIGHT
	SMOKE DETECTOR
	HOSE BIB



SCALE 1/4" = 1'-0"



# FLOOR PLAN

RESIDENCE FOR:

PRE-  
ENGINEERED  
ROCKPORT